



LR Type Approval Certificate Extension

This is to certify that Certificate No. 93/60141(E2) for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER Fire-Lite/Notifier Inc.

PLACE OF PRODUCTION One Fire-Lite Place
Clintonville Road
Northford, CT 06472
United States of America

DESCRIPTION Peripheral equipment, including analogue/addressable fire detectors and manual pull stations.

TYPES	FSP-751	Photoelectric smoke detector
	FSI-751	Ionisation smoke detector
	FST-751R	Rate of rise heat detector
	HPX-751	Harsh environment smoke detector
	FMM-1	Monitor module
	FMM-101	Monitor module
	FZM-1	Monitor module
	FCM-1	Control Module
	FRM-1	Relay module
	NBG-12 [Ⓢ]	Manual pull station
	NBG-12LX	Addressable manual pull station
	B710LP	Mounting base
	B224RB	Mounting base
	B224BI	Mounting base
	B501-BH	Mounting base with sounder.
	B501-BHT	Mounting base with temporal sounder.

[Ⓢ] may have additional end letters S, L, LSP, LOB or LA

Certificate No.	93/60141(E3)
Issue Date	19 July 2001
Expiry Date	9 December 2004
Sheet	1 of 2



J. N. Croston





APPLICATION Marine and offshore application in Category ENV1, ENV2 as defined in LR Type Approval System Test Specification No.1 1996 where the test specification is satisfactory for the intended operation

SPECIFIED STANDARD Manufacturer's Specification

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify LR of any modification or change to the equipment in order to obtain a valid certificate."

The attached Design Appraisal Document No. 93/60141(E3) forms a part of this Certificate.

All other details remain as the original Certificate No. 93/00141 to which this extension should be attached

Certificate No. 93/60141(E3)
Issue Date 19 July 2001
Expiry Date 9 December 2004
Sheet 2 of 2



J. N. Croston

