

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Rudolph J. Rinaldi, R.A., Commissioner  
MEA 117-93-E

Report of Material and Equipment Acceptance Division

Manufacturer - GS Building Systems Corp. (Edwards), Farmington, CT

Trade Name - Fire-Lite/Notifier DH150 Series Doorholders.

Product - Doorholders to be connected to automatic fire alarm.

Pertinent code Section - 27-371 (c).

Prescribed Test - UL 228.

Laboratory - Underwriters' Laboratories Inc.

Test Reports - UL ML File (6291 Issued 10/29/85 Revised 4/27/92, ML File R14531 Issued 9/18/91, File R6291 Project 73NK5754 Issued 12/12/73, Test Record No. 1 Issued 12/12/73 .

Description - The Fire-Lite/Notifier DH150 Series Doorholders to be connected to automatic fire alarms are sold by Fire-Lite/Notifier, both owned by Pittway Corporation under the following part numbers, (These units release when there is a loss of power):

Model No.	Description
DH150A	Floor Mounted 24 VAC/VDC
DH150N	Floor Mounted 120 VAC
DH154A	Flush Wall Mounted 24 VAC/VDC
DH154N	Flush Wall Mounted 120 VAC/VDC
DH158A	Surface Wall Mounted 24 VAC/VDC
DH158N	Surface Wall Mounted 120 VAC

Recommendation - That the above units connected to an automatic fire alarm system be accepted on condition that all uses, locations, and installations are in compliance with Subchapter 6 (Means of Egress) of the New York City Building Code, specifically Section 27-371 (c). All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use as provided for in Section 27-131 of the Building Code.

Final Acceptance *May 4 1993*  
Examined by *Mark [Signature]*