

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Gaston Silva, R.A., Commissioner
MEA 127-98-E

Report of Material and Equipment Acceptance Division
Manufacturer - Notifier, A Pittway Company, 12 Clintonville Road, Northford,
CT 06472-1001.

Trade Name(s) - Notifier.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - 27-958 thru 27-977, RS 17-5, ANSI/NFiPA/No. 72.

Test(s) - RS 17-5 ANSI/NFiPA No. 72; UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S635, Project 97NK40519, Volume 31, Issued March 27, 1998.

Description - The XP5-C and XP5-M transponders provide compatible Fire Alarm Control Panels (FACPs) with monitor and control functions. Each XP5 transponder communicates with one of the addressable signalling line circuit (SLC) loops of the host FACP. They can function as alarm Initiating Device Circuits (IDC), Notification Appliance Circuits (NAC), speaker circuit and telephone circuits, or relay circuits.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. the Bureau of Fire Prevention has no objections Letter dated May 14, 1998, F.P. Index No. 9805032.

Recommendation - That the above units be accepted provided that all uses, configurations, arrangements and functions, locations and installations shall comply with the New York City Building Code, specifically Subchapter 17 and with Reference Standards RS 17-3 through RS 17-3C, NFPA 72, UL 864 Standard, the U.L. Listing, the manufacturer's instructions, the Fire Department Rules, and the New York City Electrical Code, and on further that:

1. Both models operate XP5-C and XP5-M transponders may be used with any MEA approved "compatible U.L. listed" Fire Alarm Control Panels.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance July 7, 1998

Examined By Mark Jeech