

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 143-01-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, A Division of Pittway, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name – Notifier.

Product – Fire alarm equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Tests – UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S3705, Project 99NK6063, issued May 5, 1999, revised April 7, 2000 and UL letter dated May 14, 2001.

Description - Notifier's Control Unit Accessories.

Model No.	Description
FDM-1	Control Unit Accessories (Dual Monitor Module)

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated July 10, 2001, F.P. Index 0105053A.

Recommendation - That the dual monitor module be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3. The referenced product shall be used only with listed and approved fire control panels and accessories with which with compatibility has been determined by a UL test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance September 5, 2001
Examined by Mark Juchiewicz