

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

**MEA 143-00-E
Report of Material and Equipment Acceptance Division**

Manufacturer - System Sensor, A Division of Pittway, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s) - Notifier, A Division of Pittway.

Product - Fire Alarm Equipment - Smoke Duct Detector.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268A.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S911, Project 99NK38889, dated issued March 24, 2000.

Description - System Sensor, A Division of Pittway Corp. Smoke Duct Detector.

| Model Number | Description |
|--------------|---------------------|
| FSD-751P | Smoke Duct Detector |

The detector is suitable for use in ducts where the velocity of air is between 500 and 4000 ft./min.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated January 24, 2001, F.P. Index No. 0101007.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements, functions, applications and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, UL listing and the UL Standard. Model FSD-751P duct detector shall be used only with listed and approved control panels with which the compatibility has been determined by a UL test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance February 7, 2001
Examined By Mark Feeley