

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Gaston Silva, R.A., Commissioner
MEA 16-94-E Vol. VII
Report of Material and Equipment Acceptance Division**

Manufacturer - Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1001
Trade Name(s) - Fire-Lite Alarms, Inc.
Product - Fire Alarm Equipment
**Pertinent Code Section(s) - 27-958 thru 27-977, Reference Standard RS 17-5
ANSI/NFPA No. 72.**
Test(s) -RS 17-5 ANSI/NFPA No. 72; UL 864
Laboratory - Underwriters Laboratories, Inc.
**Test Report(s) - UL Multiple Listing Correlation Sheets Files S232, Issued August 21, 1992
and Revised September 8, 1998; S635 Issued January 29, 1999.**
**Description - The ADT model LCD-40L Remote Annunciator is multiple listed with the Fire-
Lite Alarms model LCD-40L (MEA 16-94-E Vol. V). The Notifier models LCD-2 X 20
and LCD-2 X 20L Remote Annunciators are multiple listed with Fire-Lite Alarms LCD-
40 and LCD-40L respectively.**

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objection letter dated March 16, 1999, F.P. Index #9903015.

Recommendation - That the above remote annunciators be accepted on condition that all uses, configurations, arrangements and functions, applications and installations comply with the New York City Building Code, specifically Subchapter 17 and Reference Standards RS 17-3 through 17-3C, inclusive, as applicable, including the NFPA 72, UL 864 Listing, manufacturer's instructions, Fire Prevention Information Bulletins and the New York City Electrical Code and on further condition that:

- 1. The aforementioned remote annunciators shall not be capable of silencing or resetting any function on the Fire Command Station or Control Panel. Also, reset of the Fire Command Station or control panel shall automatically reset the remote annunciator.**

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 5, 1999
Examined By Mark J. [Signature]