

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Gaston Silva, R.A., Commissioner
MEA 16-97-E

Report of Material and Equipment Acceptance Division

Manufacturer - Notifier, 12 Clintonville Road, Northford CT 06472-1001

Trade Name(s) -Notifier.

Product -Fire Alarm Equipment.

Pertinent Code Section(s) -

Test(s) -RS 17-5 ANSI/NFiPA No. 72; UL 864.

Laboratory -Underwriters Laboratories, Inc.

Test Report(s) - UL File S1115 Volume 30 Section 2 Issued May 23, 1996, Revised July 31, 1996,
UL File S1115 Volume 31 Section 2 Issued, July 3, 1996.

Description - The IPX-751 is an addressable, intelligent combinational photoelectric, ionization and thermal (135 degree F.) type smoke detector. It provides dual bi-color LEDs which blink green in normal operation, and illuminate steady red in alarm. The LPX 751 is an addressable, combinational intelligent laser and photoelectric type smoke detector. It also provides dual bi-color LEDs.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections Letter dated April 28, 1997, F.P. Index 9704009.

Recommendation - That the above units be accepted on condition that all uses, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and with the Reference Standard RS-17 as applicable including the NFPA as appropriate, the U.L. Listing, the manufacturer's instructions, the Fire Department Directives, and with the Electrical Code of the City of New York, and on further condition that:

1. Model LPX-751 smoke detector is for use with any listed compatible base and the base/head combination is for use only with Notifier control unit Model AFP400.

Model IPX-751 smoke detector is for use with any listed compatible base and the base/head combination are for use only with the listed Notifier compatible control unit, Model AFP400.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

Examined By

June 20, 1997
Mark Jacoby