

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Gaston Silva, R.A., Commissioner

MEA 17-96-E Vol. II

Report of Material and Equipment Acceptance Division

Manufacturer - Notifier, A Pittway Company, 12 Clintonville Road, Northford, CT 06472-1001.

Trade Name - Notifier.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - 27-968 through 27-977, RS 17-5 ANSI/NFPA No. 72.

Test(s) - RS 17-5 ANSI/NFPA No. 72; UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S635 Volume 26, Revised July 22, 1997.

Description - The model AFP-300 control unit is identical to the Notifier AFP-400 control unit (MEA 17-96-E) and uses the same equipment as the AFP-400 with the exception that the AFP-300 has only one SLC loop and the AFP-400 has two SLC loops.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections Letter dated October 22, 1997, F.P. Index No. 9709080.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements and functions, locations and installations comply with the New York City Building Code, specifically Reference Standards RS 17-3 through 17-3C inclusive, as applicable, including the NFPA 12, 12A, 12B, 13, 15, 16, 17, 17A, 72 and 2001, UL 864 Listing, the manufacturer's instructions, the Fire Department Rules 3RCNY 15-01, 15-08, 17-01 through 17-08, and the New York City Electrical Code, and on further condition that:

- a. The connection of security/burglar devices and equipment to that submitted for acceptance for fire alarm usage under this MEA application is prohibited within New York City. Such equipment and devices shall be so permanently labelled.
- b. When used as a central office control communicator/transmitter, the installation and operation of the equipment and devices listed herein shall comply with Fire Department Rule #3-RCNY 17-01 and NFPA 72-1989 and shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic smoke/heat detection alarm, sprinkler waterflow alarm, supervisory signal indications and trouble indications.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance November 18, 1997

Examined by Mark Jacoby