

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner  
MEA 173-01-E

Report of Material and Equipment Acceptance Division

Manufacturer – Notifier, One Fire-Lite Place, Northford, CT 06472-1001.

Trade Name(s) – Notifier.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – 27-968 through 27-977; RS 17-5 ANSI/NFPA No. 72

Test(s) – RS 17-5, ANSI/NFPA No. 72, UL 864.

Laboratory – Underwriters Laboratories Incorporated.

Test Report(s) – UL File S635 Project 00NK18393, Volume 2, issued February 14, 2001, revised April 25, 2001. Project 00NK18393.

Description – The ACPS-2406 (addressable charger/power supply) is an auxiliary power supply and battery charger with many unique features. Each of the four Notification Application Circuits (NAC) is individually addressable, eliminating the need for control modules. In addition, each circuit can provide notification appliance synchronization without an additional module, normally required when non-coded devices are installed.

Model No.  
ACPS-2406

Description  
Addressable Charger/Power Supply

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated June 12, 2001, F.P. Index No. 0105079.

Recommendation - That the above unit be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3 and the UL Listing. Further, the installation shall be in accordance with the manufacturer's recommendations. This unit shall be used only with listed and approved control panels with which the compatibility has been determined by a nationally recognized laboratory test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance June 22, 2001

Examined by Mark Jachy