

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Gaston Silva, R.A., Commissioner
MEA 195-97-E

Report of Material and Equipment Acceptance Division

Manufacturer - Notifier, A Pittway Company, 12 Clintonville Road,
Northford, CT 06472-1001

Trade Name(s) - CHG-120.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - 27-968, thru 27-977, RS 17-5, ANSI/NFiPA/No. 72.

Test(s) - RS 17-5 ANSI/NFiPA No. 72; UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S674 Vol. 2, Sec. 1, Project 97NK22057, Issued June 4, 1997.

Description - The model CHG-120 battery charger is designed to charge 24 AH-120 AH lead acid batteries that provide emergency standby power for a fire alarm control panel.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. the Bureau of Fire Prevention has no objections Letter dated August 7, 1997, F.P. Index 9707095.

Recommendation - That the above battery chargers, be accepted on condition that all uses, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and with Reference Standards RS 17-3 through RS 17-3C inclusive as applicable, the U.L. Listing, the manufacturer's instructions, the Fire Department Directives, and with the Electrical Code of the City of New York.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance August 26, 1997

Examined By Mark Jachun