

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division

Joel A. Miele, Sr., P.E., Commissioner

MEA 328-94-E Vol. II

Report of Material and Equipment Acceptance Division

Manufacturer - Fire-Lite Alarms, Inc. 12 Clintonville Road, Northford CT 06472.

Trade Name - Fire-Lite Alarms and ADT.

Product - Fire Alarm Equipment.

Pertinent Code Sections - 27-968 through 27-977, RS 17-5 ASI/NFiPA No. 72.

Tests - RS 17-5 ANSI/NFiPA No. 72; UL 864.

Laboratories - Underwriters Laboratories, Inc.

Test Report - UL Multiple-Listing File S232 Issued August 23, 1994, UL Report File S635 Volume 24 Section 1 Issued June 3, 1994 Revised October 4, 1994.

Description - The UDACT Digital Alarm Communicator/Transmitter is updated to include the Notifier UNI-COM and the multiple-listing of the UNI-COM with the ADT model UNI-COM. The UNI-COM is identical in construction to the UDACT except operating software is formatted for use with different listed compatible control panels and receivers. The UNI-COM transmits system status to UL Listed Central Station and Remote Station Service over a two wire telephone switching network.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections Letter dated May 15, 1995, F.P. Index No. 95040100.

Recommendation - That the above units be accepted on condition that all uses configuration, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and with Reference Standard RS-17-3, including NFPA as appropriate, UL Listing, manufacturer's instructions, Fire Department Rules and the New York City Electrical Code.

ADT UNI-Com Digital Alarm Communicator/Transmitter shall only be used with ADT Unimode 200, Unimode 4-16 and Unimode II Control Panels.

All Shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance *July 5, 1995*
Examined By *Mark J. Kelly*