

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 327-94-E Vol. III

Report of Material and Equipment Acceptance Division

Manufacturer – Notifier, A Pittway Company, One Fire-Lite Place, Northford, CT 06472-1001.

Trade Name(s) – Notifier, A Pittway Company.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) -27-958 thru 27-977, RS 17-5, ANSI/NFiPA/No. 72.

Test(s) -RS 17-5 ANSI/NFiPA No. 72; UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S635. Volume 28, issued February 9, 1988 and UL File S635, Project 99NK9218, Volume 32, issued May 21, 1999 and UL letter dated August 10, 1999.

Description – The PRN-5 is an 80 column printer and provides a record of time and date for each status change and system event. The RM-1 and RM-1SA Remote microphones provide paging capabilities to speaker systems driven by the low level audio source of the models AMG-1 and AMG-E Audio Message Generators. They are used with the following equipment:

PRN-5	Model	MEA Number
	AFP-200	104-93-E Volume III
	AFP-1010	289-91-E Volume II
	AFP-400	17-96-E
	AFP-300	17-96-E Volume II
	Noti-Fire-Net	261-93-E
	S-500	291-91-E (BSA 578-81-SA)
	S-5000	290-91-E
	AM-2020	289-91-E Volume VI

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated September 10, 1999, F.P. Index No. 9908085.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements and functions, applications and installations shall comply with the New York City Building Code, specifically Reference Standards RS 17-3 through 17-3C, NFPA 72, UL 864 Standard, the Underwriters Laboratories Inc. Listing, the manufacturer's instructions, the Fire Department Rule, and the New York City Electrical Code.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance October 13, 1999
Examined By Mark Feckin