

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Ronny A. Livian, P.E., Acting Commissioner

MEA 382-01-E

Report of Material and Equipment Acceptance Division

Manufacturer - Wheelock Inc., 273 Branchport Ave., Long Branch, New Jersey 07740.

Trade Name(s) - Notifier, Wheelock.

Product - Fire alarm equipment.

Pertinent Code Section(s) - 27-958 thru 27-977, RS 17-5 ANSI/NFiPA/No. 72.

Test(s) - RS 17-5 ANSI/NFiPA No. 72; UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL Multiple Listing ML File S635, issued November 10, 1994.

Description - The AVL-1 Audio Voice Link is a record and playback unit. It has eight contact inputs, one audio channel output, two minutes of PSRAM memory and 25 days battery backup for data retention. It is multiple listed as follows:

Basically listed for Wheelock Inc. Model No.	Multiple Listee Notifier, Division of Pittway Corp. Model No.
DV-200	AVL-1

The Digital Voice Modules (DV-200 and AVL-1) are designed to store audio signals, whether they are pre-recorded voice messages and /or coded tone signals on digital memory chips, and to transmit them when signaled by the contact closures or a computer based initiation through an RS-232 Port. The Digital Voice Modules are designed to store up to 999 voice or coded signals for signal activation by a computer input. They can also store a maximum of 256 message signals activated by dry contact closure. Inputs to the Digital Voice Module are supervised.

The Digital Voice Module (MDV-2) is designed store audio signals, whether they are pre-recorded voice messages and/or coded signals on digital voice memory chips, and to transmit them when signaled by contract closures. The Digital Voice Modules are designed to store up to 8 voice or coded signals for signal activation by contact closure.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections to equivalent model number letter dated April 27, 2001, F.P. Index #0103016A (MEA 151-92-E Vol. XXVII).

Recommendation - That the above units be accepted on conditions that all uses, configurations, arrangements and functions, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and with the Reference Standard RS 17-3 through 17-3C. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, the UL Listing, and UL 864 Standard. The above referenced voice modules shall be used only with listed and approved control panels with which the compatibility has been determined by a UL test report and on further condition that:

- 1) The installation of AVL-1 and DV-200 units shall be provided with a separate cut-out switch.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance December 18, 2001

Examined By Mark Jachnig