

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 386-02-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s) – Notifier.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Test(s) – UL 864.

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL File S3705. Volume 7, Sec. 2, issued September 19, 2001, revised September 27, 2002.

Description – The XP6-MA is intended to be connected to the signaling line circuit of a compatible fire alarm control panel. The module has up to six Class B or 3 Class A initiating loops which share a common supply from the panel's auxiliary supply. Note, if an external power supply is used, the negative of the external power supply is referenced to the negative of the auxiliary supply of the compatible control panel. This is done in order to detect ground faults on the initiating circuit.

Model Number	Description
XP6-MA	Six zone interface signaling device module

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated December 2, 2002, F.P. Index 0211035.

Recommendation - That the above equipment be accepted on condition that all uses, locations, and installations shall comply with Article 17, and Reference Standard RS-17-3 of the New York City Buildings Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer's instructions.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

March 14, 2003

Examined by

