

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 387-02-E Vol. II

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s) – Notifier.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Test(s) – UL 521.

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL Multiple Listing File No. S747, issued July 20, 2004.

Description – The products are intended to detect an abnormally high temperature.

Each unit consists of resistors, capacitors, diodes, thermistors, and transistors mounted on a printed wiring board inside an enclosure, which has an opening to the outside air. These units are for use with listed base B350LP.

Notifier Model No.	System Sensor Model No.	Description	Rating
NH-100	H355	Heat Detector	135°F
NH-100R	H355R	Heat Detector	135°F

Recommendation - That the above equipment be accepted on condition that all uses, configurations, arrangements and functions, applications, and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard RS-17-3. The referenced products shall be used only with listed and approved fire control panels and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance September 20, 2004

Examined by Donald [Signature]