

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 457-99-E

Report of Material and Equipment Acceptance Division

Manufacturer - Systems Sensor, A Division of Pittway, 3820 Stern Avenue,
St. Charles, IL. 60174

Trade Name(s) - Notifier.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268 and UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S911, Project 99NK44806 dated August 16, 1999, Vol. 22, Sec. 4; UL
File S3705, Vol. 7, Sec. 1 and UL letter dated December 9, 1999.

Description - Notifier's smoke detector and control accessories as follows:

Model Number	Description
FSI-751	Ionization smoke detector
FMM-1, FMM-101, FZM-1, FSM-101, FCM-1, FRM-1	Control Accessories

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated March 23, 2000 F.P. Index No. 9912073A.

Recommendation - That the above units be accepted on conditions that all uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, the UL Listing and UL Standard. Periodic sensitivity tests where required for the smoke detectors shall be conducted in accordance with the regulations of Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 7, 2000

Examined By Mark Jachniewicz
SD