

1 of 2 pages
CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Rudolph J. Rinaldi, R.A., Commissioner

MEA 460-92-E

Report of Materials and Equipment Acceptance Division

Manufacturer - Fire-Lite Alarms/Notifier 12 Clintonville Road, Northford, Connecticut 06472-1001.

Trade Name - Notifier, Division of Pittway Corporation System 5000. *AM2020/AFP-1010*

Product - Fire Alarm Equipment.

Pertinent Code Sections - 27-968 thru 27-977, RS 17-5 ANSI/NFIPA No. 72.

Tests - RS 17-5 ANSI/NFIPA No. 72; UL 864.

Laboratories - Underwriters Laboratories, Inc.

Test Reports - UL file S1570 issued July 18, 1990 Revised November 6, 1992 S624

Vol. 8 Sec. 1 Issued Revised June 5, 1992 S2101 Vol. 2 Sec. 1 Issued December

14, 1988 S624 Vol. 8 Sec. 1 Issued February 9, 1988 Revised February 25, 1992

S2424 Vol. 2 Sec. 1 Issued February 9, 1988 Revised May 27, 1992 September 10,

1991 S624 Vol. 8 Sec 1 Issued February 9, 1988 Revised August 13, 1992 S624

Test Record T-27 New August 13, 1992 S624 Test Record T-19 New August 13, 1992.

Description - The Notifier AM-2020 and AFP-1010 Fire Alarm Control Panels are updated with the request to include the following equipment.

Model No.	Description	UL Lab Files
PRN-3	IFC-2020/IFC-1010 80 Column Printer	S1570 Issued 7/18/90 Revised 11/6/92 S2424 Vol. 2 Sec. 1 Issued 2/9/88 Revised 5/27/92
MPS-24A	Power Supply	S624 Vol. 8 Sec. 1 Issued 2/9/88 Revised 6/5/92
FDX-551	Heat Detector	S2101 Vol. 2 Sec. 1 Issued 12/14/88
SDX-551TH	Photoelectric Detector, w/135 degree Thermal Detector	S624 Vol. 8 Sec. 1 Issued 2/9/88 Revised 2/25/92 S624 Test Record No. 21 New 2/25/92
STS-1	Tamper Switch	S624 Vol. 8 Sec. 1 Issued 2/9/88 Revised 6/5/92 S624 Test Record No. 25 New 6/5/92
MON-1	Monitor	S2424 Vol. 2 Sec. 1 Issued 2/9/88 Revised 5/27/92 S624 Vol. 8 Sec. 1 Issued 2/9/88 Revised 6/5/92

T-70 Set-Up Transformer, and Audio
 ACT-1 Audio Coupling transformer

S624 Vol. 8 Sec. 1
 Issued 2/9/88 Revised 8/13/92
 S624 Vol. 11 Sec. 1 Issued
 5/17/88 Revised 8/13/92 S624
 Issued 2/9/88 Test Record
 T-27 New 8/13/92 S624 Issued
 5/17/88 Test Record T-19 New
 8/13/92

Recommendation - That the above units be accepted, provided that all uses, locations, and installations shall comply with Article 17, Reference Standard RS-17 of the New York City Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives, the U.L. Listing and the manufacturer's instructions.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance April 23, 1993
 Examined by: Mark J. [Signature]