

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Rudolph J. Rinaldi, R.A., Commissioner

MEA 460-92-E Vol. III

Report of Materials and Equipment Acceptance Division

Manufacturer - Fire-Lite Alarms/Notifier 12 Clintonville Road, Northford, Connecticut 06472-1001.

Trade Name - Notifier, Division of Pittway Corporation

Product - Fire Alarm Equipment.

Pertinent Code Sections - 27-968 thru 27-977, RS 17-5 ANSI/NFPA No. 72.

Tests - RS 17-5 ANSI/NFPA No. 72; UL 864.

Laboratories - Underwriters Laboratories, Inc.

Test Reports - UL file S635 issued April 13, 1993 Project 92NK29306 Test Record No. 1 issued April 13, 1993.

Description - The MMX-2 Monitor Module, supports 2 wire detectors and may support normally-open circuit initiating devices.

Pursuant to "Promulgation of the Rules relating to material and equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections. F.P. letter dated June 22, 1993 F.P. Index No. E274193.

Recommendation - That the above units be accepted, on condition that all uses uses locations, and installations comply with the New York City Building Code, specifically Subchapter 17 and with the Reference Standard RS-17 specifically RS 17-2 through 17-3C inclusive and applicable NFPA standard as refereed to by Code. The U.L. Listing, the manufacturer's instructions, the Fire Department Directives, and with the Electrical Code of the City of New York, and on further condition that:

The use of the MMX-2 shall be restricted to connection only with BSA/MEA approved fire alarm control units, auxiliary devices and peripheral equipment considered compatible.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance September 23, 1993
Examined by Mark J. Kelly