



---

## GTPR.R11746 Door Holders

[Page Bottom](#)

[Questions?](#)

---

### Door Holders

[See General Information for Door Holders](#)

#### NOTIFIER

R11746

12 CLINTONVILLE RD  
NORTHFORD, CT 06472 USA

Electro-magnetic door holders rated 0.068 amp, 24 v, dc, 0.180 amp, 12 v, dc, 0.017 amp, 120 v, ac, 0.080 amp, 24 v, ac, 0.140 amp, 12 v, ac, and 0.009 amp, 250 v, ac.

Models FM980, -996, -998 with suffix "-24" rated 24 v, ac/dc.

Models FM980, -996, -998 with suffix "-120" rated 120 v.

Models FM980, -996, -998.

Models DH150A, -154A, -158A rated 24 v, ac/dc.

Models DH150N, -154N, -158N rated 120 v, ac.

Models 1501-AQ, 1502-AQ, 1504-AQ, 1505-AQ, 1508-AQ, 1509-AQ rated 24 v, ac/dc.

Models 1501-N5, 1502-N5, 1504-N5, 1505-N5, 1508-N5, 1509-N5 rated 120 v, ac.

Models 1501-E1, 1502-E1, 1504-E1, 1505-E1, 1508-E1, 1509-E1 rated 12 v, dc, 0.17 amp.

Models 1501-G1, 1502-G1, 1504-G1, 1505-G1, 1508-G1, 1509-G1 rated 24 v, dc, 0.07 amp.

Models 1501-E5, 1502-E5, 1504-E5, 1505-E5, 1508-E5, 1509-E5 rated 12 v, ac, 0.15 amp.

Last Updated on 20000717

---

[Page Top](#)

[Notice of Disclaimer](#)

[Questions?](#)

[UL Listed and Classified  
Products](#)

[UL Recognized  
Components](#)

[Products Certified  
for Canada](#)

This page and all contents are Copyright © 2004 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2004 Underwriters Laboratories Inc.®"