



# UIRV.E40575

## Heat-automatic Fire Detectors for Use in Hazardous Locations

[Page Bottom](#)

[Questions?](#)

## Heat-automatic Fire Detectors for Use in Hazardous Locations

[See General Information for Heat-automatic Fire Detectors for Use in Hazardous Locations](#)

### NOTIFIER

E40575

12 CLINTONVILLE RD  
NORTHFORD, CT 06472 USA

**Class I, Groups C and D; Class II, Groups E, F and G.**

Oper Principle	Model No.	Temp Rating F	Spacing Ft	
			Smooth Ceiling	to Wall or Partition
ROR-FT	302-EPM	140, 180	40	20
ROR-FT	EP51	136	50	25
ROR-FT	EP52	190	50	25
FT	EP53	136	15	7.5
FT	EP54	190	15	7.5

Last Updated on 20000427

[Page Top](#)

[Notice of Disclaimer](#)

[Questions?](#)

[UL Listed and Classified  
Products](#)

[UL Recognized  
Components](#)

[Products Certified  
for Canada](#)

This page and all contents are Copyright © 2004 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2004 Underwriters Laboratories Inc.®"